



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
Phone (207) 784-5354 website [www.allaboratory.com](http://www.allaboratory.com)

## Laboratory Report

Asa C Adams School  
6 Goodridge Drive  
Orono, ME 04473

Date Printed: 05/02/2022  
Work Order #: 2203-03356  
Client Job #: 339  
Date Received: 03/24/2022  
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the \* symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

**A & L Laboratory:**  
*Identified by ME in Analyst Column*  
155 Center Street, Auburn, Maine 04210  
[www.allaboratory.com](http://www.allaboratory.com)

**Granite State Analytical Services LLC:**  
*Identified by NH in Analyst Column*  
22 Manchester Road, Derry, NH 03038  
[www.granitestateanalytical.com](http://www.granitestateanalytical.com)

### ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

### SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche  
Laboratory Director



# A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210  
 Phone (207) 784-5354 website www.allaboratory.com

## CERTIFICATE OF ANALYSIS FOR DRINKING WATER

**DATE PRINTED:** 05/02/2022  
**CLIENT NAME:** Asa C Adams School

**CLIENT ADDRESS:** 6 Goodridge Drive  
 Orono, ME 04473

**METHOD:** EPA 200.8  
**EPA ACTION LEVEL:** 15 ppb  
**MAINE GUIDELINE:** 4 ppb  
**REPORTING LIMIT:** 1 ppb

**DATE AND TIME RECEIVED:** 03/24/2022 09:20AM  
**ANALYSIS PACKAGE:** Maine Schools-Lead  
**RECEIPT TEMPERATURE:** 16° CELSIUS  
**CLIENT JOB #:** 339

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2203-03356-001	Classroom 1	I	OT	03/22/2022 06:07AM	<1	ppb			DG-NH	04/30/2022 04:00AM
2203-03356-002	Classroom 2	I	OT	03/22/2022 06:10AM	<1	ppb			DG-NH	04/30/2022 04:03AM
2203-03356-003	Classroom 3	I	OT	03/22/2022 06:12AM	<1	ppb			DG-NH	04/30/2022 04:07AM
2203-03356-004	Classroom 8	I	OT	03/22/2022 05:59AM	7.7	ppb			DG-NH	04/30/2022 04:18AM
2203-03356-005	Classroom 10	I	OT	03/22/2022 06:01AM	6.2	ppb			DG-NH	04/30/2022 04:32AM
2203-03356-006	Classroom 12	I	OT	03/22/2022 05:54AM	1.6	ppb			DG-NH	04/30/2022 04:36AM
2203-03356-007	classroom 15	I	OT	03/22/2022 05:52AM	1.5	ppb			DG-NH	04/30/2022 04:40AM
2203-03356-008	Classroom 17	I	OT	03/22/2022 05:49AM	4.1	ppb			DG-NH	04/30/2022 04:43AM
2203-03356-009	Classroom 19	I	OT	03/22/2022 05:45AM	4.0	ppb			DG-NH	04/30/2022 04:47AM
2203-03356-010	Classroom 20	I	OT	03/22/2022 05:47AM	4.9	ppb			DG-NH	04/30/2022 04:50AM
2203-03356-011	Classroom 29	I	OT	03/22/2022 06:14AM	29.8	ppb			DG-NH	04/30/2022 04:54AM
2203-03356-012	Classroom 30	I	OT	03/22/2022 06:16AM	7.2	ppb			DG-NH	04/30/2022 04:58AM
2203-03356-013	Classroom 32	I	OT	03/22/2022 06:18AM	6.9	ppb			DG-NH	04/30/2022 05:01AM
2203-03356-014	Classroom 33	I	OT	03/22/2022 06:19AM	24.1	ppb			DR-NH	04/29/2022 06:38PM
2203-03356-015	Classroom 34	I	OT	03/22/2022 06:20AM	26.2	ppb			DR-NH	04/29/2022 06:41PM
2203-03356-016	Classroom 35	I	OT	03/22/2022 06:22AM	6.1	ppb			DR-NH	04/29/2022 06:44PM
2203-03356-017	Classroom 36	I	OT	03/22/2022 06:24AM	2.8	ppb			DR-NH	04/29/2022 06:47PM
2203-03356-018	Classroom 39	I	OT	03/22/2022 06:26AM	4.3	ppb			DR-NH	04/29/2022 06:50PM
2203-03356-019	Classroom 40	I	OT	03/22/2022 06:27AM	3.8	ppb			DR-NH	04/29/2022 06:58PM
2203-03356-020	Classroom 41	I	OT	03/22/2022 06:28AM	7.4	ppb			DR-NH	04/29/2022 07:01PM
2203-03356-021	Classroom 42	I	OT	03/22/2022 06:30AM	12.2	ppb			DR-NH	04/29/2022 07:04PM
2203-03356-022	Fountain by Library	I	DWF	03/22/2022 06:32AM	<1	ppb			DR-NH	04/29/2022 07:07PM
2203-03356-023	Kitchen 3 bay Sink	I	KF	03/22/2022 05:57AM	<1	ppb			DR-NH	04/29/2022 07:16PM
2203-03356-024	Kitchen Vegetable Wash	I	KF	03/22/2022 05:56AM	<1	ppb			DR-NH	04/29/2022 07:19PM
2203-03356-025	Fountain in Gym	I	DWF	03/22/2022 06:03AM	<1	ppb			DR-NH	04/29/2022 07:22PM
2203-03356-026	2nd Fountain in Gym	I	DWF	03/22/2022 06:05AM	<1	ppb			DR-NH	04/29/2022 07:25PM

Rebecca L. Labranche  
 Laboratory Director